



ATLAS WIRE LLC.
 9525 RIVER STREET
 SCHILLER PARK, ILLINOIS 60176
 (847) 678-1210
 (847) 678-1281 FAX
 www.atlaswirecorp.com



Atlas Wire, LLC
 Registered to ISO9001 and TS16949
 Schiller Park, IL 60176
 Reference No. 10000854
 Tucson, AZ 85714
 Reference No. 10003647

MATERIAL SPECIFICATION SHEET

#12 19/25 TC .017" PVC
RoHS Compliant
MIL-16878/2 TYPE C
105c - 1,000 VOLTS

CONDUCTOR:	#12 19/25 TINNED COPPER 1-1/4" UNILAY	
	NOMINAL O.D.	.090"
	APPROXIMATE CIRCULAR MILL AREA	6,088
	WEIGHT PER THOUSAND FEET	18.80#
	BASIC SPECIFICATION	ASTM B-8 ASTM B-286
PVC:	TEMPERATURE RATING	105c
	VOLTAGE RATING	1,000 VOLTS
	ELONGATION	330% AVG.
	SPECIFIC GRAVITY	1.32
	DUROMETER (SHORE)	91 (A)
	TENSILE STRENGTH	2450 PSI AVG
	SPARK TESTED	7,100 VOLTS
	OXYGEN INDEX	28
	BRITTLE POINT	-24c
	FINISHED O.D.	.124"
WEIGHT PER 1,000 FEET	22.24#	

REVISION: MIL-DTL- 16878G - PRINT REQUIRED*

* OUR STANDARD IS PRINTED, IF NO PRINTING IS PREFERRED
 PLEASE CALL THAT OUT AT TIME OF ORDER.