



ATLAS WIRE LLC.
 9525 RIVER STREET
 SCHILLER PARK, ILLINOIS 60176
 (847) 678-1210
 (847) 678-1281 FAX
 www.atlaswirecorp.com



Atlas Wire, LLC
 Registered to ISO9001 and TS16949
 Schiller Park, IL 60176
 Reference No. 10000854
 Tucson, AZ 85714
 Reference No. 10003647

MATERIAL SPECIFICATION SHEET

#12 19/25 TC .037" PVC
RoHS Compliant
MIL-16878/3 TYPE D
105c - 3,000 VOLTS

CONDUCTOR:	#12 19/25 TINNED COPPER 1/2" UNILAY	
	NOMINAL O.D.	.090"
	APPROXIMATE CIRCULAR MILL AREA	6.088
	WEIGHT PER THOUSAND FEET	18.80#
	BASIC SPECIFICATION	ASTM B-8 ASTM B-286
PVC:	TEMPERATURE RATING	105c
	VOLTAGE RATING	3,000 VOLTS
	ELONGATION	320% AVG.
	SPECIFIC GRAVITY	1.34
	DUROMETER (SHORE)	85 (A)
	TENSILE STRENGTH	2450 PSI AVG
	SPARK TESTED	10,000 VOLTS
	OXYGEN INDEX	25
	BRITTLE POINT	-25c
	FINISHED O.D.	.160"
WEIGHT PER 1,000 FEET	27.67#	

REVISION: MIL-DTL- 16878G - PRINT REQUIRED*

* OUR STANDARD IS PRINTED, IF NO PRINTING IS PREFERRED
 PLEASE CALL THAT OUT AT TIME OF ORDER.