



ATLAS WIRE LLC.
9525 RIVER STREET
SCHILLER PARK, ILLINOIS 60176
(847) 678-1210
(847) 678-1281 FAX
www.atlaswirecorp.com



Atlas Wire, LLC
Registered to ISO9001 and TS16949
Schiller Park, IL 60176
Reference No. 10000854
Tucson, AZ 85714
Reference No. 10003647

MATERIAL SPECIFICATION SHEET

#16 19/29 TC .010" PVC .004" NYLON
RoHS COMPLIANT
MIL-16878/17 TYPE BN
105c - 600 VOLTS

CONDUCTOR:	#16 19/29 TINNED COPPER 3/4" UNILAY NOMINAL O.D. .057" APPROXIMATE CIRCULAR MILL AREA 2.409 WEIGHT PER THOUSAND FEET 7.50# BASIC SPECIFICATION ASTM B-8 ASTM B-286
PVC:	TEMPERATURE RATING 105c VOLTAGE RATING 600 VOLTS ELONGATION 300% AVG. SPECIFIC GRAVITY 1.34 DUROMETER (SHORE) 47 (D) TENSILE STRENGTH 3000 PSI AVG SPARK TESTED 5,700 VOLTS OXYGEN INDEX 25 BRITTLE POINT -29c FINISHED O.D. .077" WEIGHT PER 1,000 FEET 8.76#
NYLON:	ELONGATION 300% TENSILE STRENGTH 7400 PSI @ 50% RELATIVE HUMIDITY SPECIFIC GRAVITY 1.13 OVERALL DIAMETER .085" WEIGHT PER M FEET 9.22#
REVISION:	MIL-DTL-16878G - PRINT REQUIRED*

* OUR STANDARD IS PRINTED, IF NO PRINTING IS PREFERRED
PLEASE CALL THAT OUT AT TIME OF ORDER.

MEETS ALL REQUIREMENTS LISTED ON THE MIL-DTL-16878/17B DETAIL SPECIFICATION SHEET WITH THE EXCEPTION OF ATLAS CONDITIONING FOR THE HEAT RESISTANCE TEST AT 136c.

www.atlaswirecorp.com

Revision 02/22/16